

... Fire Protection by Computer Design

Master Craft Plumbing
887 Brentwood Dr.
Daytona beach, FL 32117
386-252-7047

Job Name : DME - Light Hazard Computer Lab Calc #5
Building :
Location :
System :
Contract :
Data File : DME - Calc #5 - 13R Computer Lab-.WXF

CURTIS ENGINEERING SERVICE, LLC - CA#31561
JAMES M. CURTIS, P.E. - PE#37912
29775 BAYHEAD ROAD
DADE CITY, FLORIDA 33523
ENGINEER OF RECORD


Water Supply Curve C

Master Craft Plumbing
DME - Light Hazard Computer Lab Calc #5

Page 1
Date 4/15/20

City Water Supply:
C1 - Static Pressure : 73
C2 - Residual Pressure: 66
C2 - Residual Flow : 1140

Demand:
D1 - Elevation : 3.465
D2 - System Flow : 60.393
D2 - System Pressure : 44.819
Hose (Demand) : _____
D3 - System Demand : 60.393
Safety Margin : 28.150



Fittings Used Summary

Master Craft Plumbing
DME - Light Hazard Computer Lab Calc #5

Page 2
Date 4/15/20

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fhc *	1/2 in FlexHead - 4 Ft Long	0	0	24					0	0	0	0	0	0	0	0	0	0	0	0	0
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zac	Ames 2000SS	Fitting generates a Fixed Loss Based on Flow																			

Unit Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Master Craft Plumbing
DME - Light Hazard Computer Lab Calc #5

Page 3
Date 4/15/20

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
S51	10.0	5.6	7.0	na	14.82	0.1	105	7.0
S52	10.0	5.6	7.41	na	15.25	0.1	105	7.0
S53	10.0	5.6	7.05	na	14.87	0.1	105	7.0
S54	10.0	5.6	7.62	na	15.46	0.1	105	7.0
51	10.75		8.92	na				
52	10.75		9.45	na				
53	10.75		9.43	na				
54	10.75		9.97	na				
501	10.75		13.81	na				
502	10.75		14.4	na				
202	10.75		19.04	na				
203	10.75		21.71	na				
204	14.75		20.88	na				
403	14.75		24.18	na				
404	14.75		26.18	na				
405	10.75		28.31	na				
406	10.75		29.99	na				
TOR	10.75		30.94	na				
BOR	2.0		38.62	na				
U1	-4.0		41.22	na				
U2	-4.0		41.23	na				
U3	-4.0		41.24	na				
U4	-4.0		41.27	na				
BF1	2.0		38.68	na				
BF2	2.0		42.8	na				
U5	-4.0		45.4	na				
U6	-4.0		45.41	na				
M1	-4.0		45.41	na				
M2	-4.0		47.41	na				
S	2.0		44.82	na				

The maximum velocity is 11.86 and it occurs in the pipe between nodes 502 and 202

Final Calculations - Hazen-Williams - 2007

Master Craft Plumbing
DME - Light Hazard Computer Lab Calc #5

Page 4
Date 4/15/20

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
*SPRINKLER DROP PENDENTS										
S51	14.82	1.049	Fhc	24.0	1.000	7.000			K Factor = 5.60	
to		120.0	T	5.0	29.000	-0.325				
51	14.82	0.0747		0.0	30.000	2.241			Vel = 5.50	
	0.0									
	14.82					8.916			K Factor = 4.96	
S52	15.25	1.049	Fhc	24.0	1.000	7.413			K Factor = 5.60	
to		120.0	T	5.0	29.000	-0.325				
52	15.25	0.0788		0.0	30.000	2.364			Vel = 5.66	
	0.0									
	15.25					9.452			K Factor = 4.96	
S53	14.87	1.049	Fhc	24.0	2.000	7.047			K Factor = 5.60	
to		120.0	2T	10.0	34.000	-0.325				
53	14.87	0.0752		0.0	36.000	2.707			Vel = 5.52	
	0.0									
	14.87					9.429			K Factor = 4.84	
S54	15.46	1.049	Fhc	24.0	2.000	7.624			K Factor = 5.60	
to		120.0	T	5.0	31.000	-0.325				
54	15.46	0.0809	E	2.0	33.000	2.669			Vel = 5.74	
	0.0									
	15.46					9.968			K Factor = 4.90	
*										
*BRANCHES										
51	14.82	1.049		0.0	7.167	8.916				
to		120.0		0.0	0.0	0.0				
52	14.82	0.0748		0.0	7.167	0.536			Vel = 5.50	
52	15.24	1.049	T	5.0	10.750	9.452				
to		120.0		0.0	5.000	0.0				
501	30.06	0.2766		0.0	15.750	4.356			Vel = 11.16	
	0.0									
	30.06					13.808			K Factor = 8.09	
*										
53	14.87	1.049		0.0	7.167	9.429				
to		120.0		0.0	0.0	0.0				
54	14.87	0.0752		0.0	7.167	0.539			Vel = 5.52	
54	15.46	1.049	T	5.0	10.750	9.968				
to		120.0		0.0	5.000	0.0				
502	30.33	0.2811		0.0	15.750	4.427			Vel = 11.26	
	0.0									
	30.33					14.395			K Factor = 7.99	
*										
*CROSSMAIN										
501	30.06	1.442		0.0	10.000	13.808				
to		120.0		0.0	0.0	0.0				
502	30.06	0.0587		0.0	10.000	0.587			Vel = 5.91	
502	30.33	1.442	T	7.432	14.333	14.395				
to		120.0		0.0	7.432	0.0				
202	60.39	0.2135		0.0	21.765	4.646			Vel = 11.86	

Final Calculations - Hazen-Williams

Master Craft Plumbing
DME - Light Hazard Computer Lab Calc #5

Page 5
Date 4/15/20

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftn'g's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 60.39					19.041		K Factor = 13.84	
*									
*FEED MAIN									
202 to 203	60.39	1.682 120.0 0.1009	E	4.95 0.0 0.0	21.500 4.950 26.450	19.041 0.0 2.668		Vel = 8.72	
203 to 204	0.0 60.39	1.682 120.0 0.1008	E	4.95 0.0 0.0	4.000 4.950 8.950	21.709 -1.732 0.902		Vel = 8.72	
204 to 403	0.0 60.39	1.682 120.0 0.1009		0.0 0.0 0.0	32.750 0.0 32.750	20.879 0.0 3.303		Vel = 8.72	
403 to 404	0.0 60.39	1.682 120.0 0.1009	E	4.95 0.0 0.0	14.833 4.950 19.783	24.182 0.0 1.996		Vel = 8.72	
404 to 405	0.0 60.39	1.682 120.0 0.1008		0.0 0.0 0.0	4.000 0.0 4.000	26.178 1.732 0.403		Vel = 8.72	
405 to 406	0.0 60.39	2.157 120.0 0.0300	2E T	12.307 12.307 0.0	31.083 24.614 55.697	28.313 0.0 1.673		Vel = 5.30	
406 to TOR	0.0 60.39	2.157 120.0 0.0300	E T	6.153 12.307 0.0	13.167 18.460 31.627	29.986 0.0 0.950		Vel = 5.30	
	0.0 60.39					30.936		K Factor = 10.86	
*									
*RISER									
TOR to BOR	60.39	2.157 120.0 0.0300	Fsp B S	0.0 7.384 13.537	8.750 20.921 29.671	30.936 6.790 0.891		* Fixed Loss = 3 Vel = 5.30	
BOR to U1	0.0 60.39	6.16 140.0 0.0001	E	20.084 0.0 0.0	16.000 20.084 36.084	38.617 2.599 0.004		Vel = 0.65	
U1 to U2	0.0 60.39	5.86 150.0 0.0002	E	17.893 0.0 0.0	47.250 17.893 65.143	41.220 0.0 0.010		Vel = 0.72	
U2 to U3	0.0 60.39	5.86 150.0 0.0002	T	38.342 0.0 0.0	57.500 38.342 95.842	41.230 0.0 0.015		Vel = 0.72	
U3 to U4	0.0 60.39	5.86 150.0 0.0002	2E	35.786 0.0 0.0	137.667 35.786 173.453	41.245 0.0 0.027		Vel = 0.72	
U4 to BF1	0.0 60.39	6.16 140.0 0.0001	E	20.084 0.0 0.0	6.000 20.084 26.084	41.272 -2.599 0.003		Vel = 0.65	

Final Calculations - Hazen-Williams

Master Craft Plumbing
DME - Light Hazard Computer Lab Calc #5

Page 6
Date 4/15/20

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
BF1	0.0	6.16	E	20.084	5.000	38.676			
to		140.0	Zac	0.0	20.084	4.120		* Fixed Loss = 4.12	
BF2	60.39	0.0002		0.0	25.084	0.004		Vel = 0.65	
BF2	0.0	6.16	E	20.084	6.000	42.800			
to		140.0		0.0	20.084	2.599			
U5	60.39	0.0001		0.0	26.084	0.003		Vel = 0.65	
U5	0.0	5.86	E	17.893	3.500	45.402			
to		150.0	T	38.342	56.235	0.0			
U6	60.39	0.0002		0.0	59.735	0.009		Vel = 0.72	
U6	0.0	5.86		0.0	7.000	45.411			
to		150.0		0.0	0.0	0.0			
M1	60.39	0.0001		0.0	7.000	0.001		Vel = 0.72	
M1	0.0	5.86	2G	7.668	3.000	45.412			
to		150.0		0.0	7.668	2.000		* Fixed Loss = 2	
M2	60.39	0.0002		0.0	10.668	0.002		Vel = 0.72	
M2	0.0	7.68	E	22.555	17.500	47.414			
to		150.0	G	5.012	71.424	-2.599			
S	60.39	0.0	T	43.857	88.924	0.004		Vel = 0.42	
	0.0								
	60.39					44.819		K Factor = 9.02	