

August 21, 2019

MEMORANDUM

FL CERTIFICATE OF AUTHORIZATION: 6106

To: Judith A. Rees, C.P.M, A.P.P.
Embry-Riddle Aeronautical University

From: Gary A. Wilkerson, P.E.
Salas O'Brien

Reference: Embry-Riddle Aeronautical University Print Shop
SOBE #19005

Subject: Addendum 1 Narrative

The following changes were made to the Electrical Sheets.

Sheet E0.1 Added Photocell symbol to the lighting legend. Added fixture type S2 to the Lighting Fixture Schedule.

Sheet E1.1 Relocated the Utility Meter to the East side of the building and added CT Cabinet. Rerouted MDP feeder through the CT Cabinet.

 Added Panel LCP and Parking Light Pole and interconnecting conduit and conductor.

Sheet E1.2 Changed notes to clarify scope of data/phone systems.

 Relocated Utility Meter and added CT Cabinet to East Wall.

 Added Panel LCP.

Sheet E1.3 Added switch adjacent to North door in Vestibule 110.

 Added Photocell to North exterior wall.

 Revised control switch leg on exterior lights, and Vestibule 110.

 Updated fixture type in Rooms 107 and 105.

Sheet E1.4 New sheet.



- Sheet E5.1 Revised Detail 4 to include CT Cabinet.
- Sheet E5.2 New Sheet.
- Sheet E6.1 Added CT Cabinet and revised MDP feeders in the Panel Feeder Schedule.

Added LCP and Parking Light feeders in Equipment Feeder Schedule.

Added CT Cabinet, Panel LCP, and Photocell to Riser diagram and revised Reference Notes.
- Sheet E7.1 Added Panel LCP schedule, and revised schedules LP1 and MDP for added load.

END OF DOCUMENT

